


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Connectors
Name and address of the applicant	TECHNO S.r.l. Via Bancora e Rimoldi, 27 22070 Guanzate (CO) Italy
Name and address of the manufacturer	TECHNO S.r.l. Via Bancora e Rimoldi, 27 22070 Guanzate (CO) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 TECHNO S.r.l. Via Bancora e Rimoldi, 27 22070 Guanzate (CO) Italy
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	2P+E or 3P, rated current: 10 A, rated voltage: 500 V (2P+E) or 250 V (3P) degree of protection: IP68 (3 bar for 1 hour) / IP66 temperature limits: -40/125 °C, pollution degree: 2, overvoltage category: II rated impulse voltage: 4 kV (2P+E) or 2,5 kV (3P) (see also pages 19, 20 and 21 of Test Report No. MI19-0047388-01)
Trademark (if any)	 Techno
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	series TH381 (see also Additional Sheet and page 5 of Test Report No. MI19-0047388-01)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 -
A sample of the product was tested and found to be in conformity with	IEC 61984:2008
As shown in the Test Report Ref. No. which forms part of this Certificate	MI19-0047388-01

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-20138 Milano, Italy